

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 196

Dated: 06/03/25

It is certified that an inspection team headed by S.D.L.W.O.T.M.L. UTS BARKOT

(Name of Officers with designation) from Mr. Sehan Singh (Lab. Chemist) PHED

inspected the Shri Guru Ram Rai Public School, Purola

(Name & Address of the school) on 03/03/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 72/UTS/SDWL/OTML/24-25 dated 05/03/2025

of S.D.L.W.O.T.M.L. UTS BARKOT (PHED Lab) certified that the

S.G.R.R. Public School, Purola (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till SIX Month

Technical Manager
Sub. Divisional Level
WQTM-LAB

Signature with Seal: En. Kuldeep Bhalwan

Name : Barkot

Designation : Lab Incharge

Name & Address of the Office / Department : Uttarakhand
Jal Sansthan, Barkot, Uttarakashi.

To Shri Guru Ram Rai
Public School, Purola
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


Principal
Shri Guru Ram Rai
Public School
Purola (Uttarakashi)



Sub Divisional Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Badkot
E-mail: ujspurola@gmail.com

Test Report ID: 72/UJS/SDLWQTML/2024-25

Dated: 05/03/2025

Name and Address of Organization/ Customer	Shri Guru Ram Rai Public School Purola, Uttarkashi		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample collected from SGRR Purola
Reference Sample Identification:	SDWQTML/UJS/SGRR-02		Date of Start of Analysis: 03/03/2025
			Date of End of Analysis: 04/03/2025
Date and Time of Sample Received: 03/03/2025 & 12:00 PM	Sample Collected by:		Customer

WATER QUALITY TEST REPORT


SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (IS10500: 2012)	Permissible Limit (IS10500:2012) in the Absence of alternative source	Std. Test Method
1.	pH at 25°C	7.94	6.5 to 8.5	No Relaxation	IS 3025 (Part 11) 2022 Electrometric method
2.	Total Dissolved Solids (TDS), mg/L, Max	109.4	500	2000	IS 3025 (Part 16), 2023 Gravimetric Method
3.	Turbidity, NTU, Max	0.35	1	5	IS 3025 (Part 10), 2023 Nephelometric Method
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	40	200	600	IS 3025 (Part 23), 2023, Titrimetric Method
5.	Total Hardness (as CaCO ₃), mg/L, Max	94	200	600	IS 3025 (Part 21), 2009 RA:2019, EDTA Titrimetric Method
6.	Chloride, mg/L, Max	26.73	250	1000	IS 3025 (Part 32), 2019 Argentometric Method
7.	Color, Hazen, Max	Less than 05	5	15	IS 3025 (Part 4): 2021 Platinum Cobalt (Visual Comparison)
8.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2022
9.	Calcium (as Ca), mg/L, Max	29.6	75	200	IS 3025 (Part 40), 2023 EDTA Titrimetric Method
10.	Magnesium (as Mg), mg/L, Max	4.86	30	100	APHA 24 th -3500-Mg Method B: 2023 Calculation method
11.	Total Coliform Bacteria	Absent	Absent	Absent	MPN/100(ml)
12.	E.Coli Bacteria	Absent	Absent	Absent	MPN/100(ml)

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.


Principal

Shri Guru Ram Rai
Public School
Purola (Uttarkashi)

-End of Report-


Technical Manager
Sub. Divisional Level
WQTM-LAB
Uttarakhand Jal Sansthan
Barkot

- The results listed refer only to tested sample and specific parameters.
- This certificate is not to be reproduced wholly or in part for promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.